



LOCKLEAR, LOCKLEAR & JACOBS, PLLC

P.O. Box 3119 Pembroke, NC 28372 Phone: (910) 774-9306 Fax: (866) 649-7235

April 16, 2015

Fayetteville Regional Airport
400 Airport Road
Fayetteville, NC 28306

Subject: Lead Sample Results
 400 Airport Road
 Fayetteville, NC 28306

Dear Mr. Johnson:

Locklear, Locklear, & Jacobs, PLLC (LL&J) is pleased to submit this letter for our limited lead sampling event for the facility located at 400 Airport Road, North Carolina (Subject Site/Subject Property).

An Environmental Technician of LL&J, Wayne Parker collected samples on April 6, 2015, which included four (4) paint chip samples. The collected samples were placed into sealed bags/containers and shipped to CEI Labs located at 107 New Edition Court, Cary, NC 27511, NC for analyses. Chain-of-custody control was maintained on the samples from collection until delivery to the laboratory.

According to laboratory analytical results, Lead levels were below (see attached analytical results) the EPA action level of 0.5% mg/kg. These services are designed to provide an analytical tool to assist the client. LL&J and its subcontractor CEI Labs and their employees/representatives bear no responsibility for the actual condition of the structure or safety of this site pertaining to lead based paints and/or lead hazards regardless of the actions taken by the survey team or the client.

Locklear, Locklear, & Jacobs, PLLC appreciates the opportunity to provide our services on this project. Please do not hesitate to call if you have any questions or if we may be of service in the future.

A handwritten signature in blue ink, appearing to read "Wayne Parker".

Sincerely,
Wayne Parker
Locklear, Locklear, & Jacobs, PLLC



CEI Labs
107 New Edition Court, Cary, NC 27511
Phone: (919) 481-1413 Fax: (919) 481-1442

LABORATORY REPORT

LEAD IN PAINT

Client: Wayne Parker
5057 Tangerine Dr.
Fayetteville, NC 28304

CEI Lab Code: C15-0136
Received: 04-08-15
Analyzed: 04-13-15
Reported: 04-13-15

Project: Fayetteville Regional Airport


ANALYSIS METHOD: EPA SW846 7000B

CLIENT ID	CEI LAB ID	PPM (µg/g)	CONCENTRATION % BY WEIGHT
1	CA50831	<35	<0.0035
2	CA50832	<58	<0.0058
3	CA50833	52	0.0052
4	CA50834	67	0.0067

ANALYSIS METHOD: EPA SW846 7000B

CLIENT ID	CEI LAB ID	PPM (µg/g)	CONCENTRATION % BY WEIGHT
-----------	---------------	------------	------------------------------

Reviewed By:



Tianbao Bai, Ph.D.
Laboratory Director

This method has been validated for sample weights of 0.020g or greater. When samples with a weight of less than that are analyzed those results fall outside of the scope of accreditations.

*** The analysis of composite wipe samples as a single samples is not included under AIHA accreditation.**

Minimum reporting limit is 20 µg total lead. Sample results denoted with a "less than" (<) sign contain less than 20.0 µg total lead, based on a 40ml sample volume.

Lead samples are not analyzed by CEI Labs Lead samples are submitted to an AIHA ELLAP accredited laboratory for lead analysis of soil, dust, paint, and TCLP samples.

Laboratory results represent the analysis of samples as submitted by the client. Information regarding sample location, description, area, volume, etc., was provided by the client. Unless notified in writing to return samples, CEI Labs discards client samples after 30 days. This report shall not be reproduced, except in full, without the written consent of CEI Labs.

**REGULATORY
LIMITS**

OSHA Standard: No safe limit.
Consumer Products Safety Standard: Greater than 0.06% lead by weight.
Federal Lead Standard / HUD: 0.5% lead by weight.

LEGEND

µg = microgram
ml = milliliter
ppm = parts per million
Pb = lead
g = grams
wt = weight

End of Report



107 New Edition Court, Cary, NC 27511
 Tel: 866-481-1412; Fax: 919-481-1442

METALS CHAIN OF CUSTODY

LAB USE ONLY:	
CEI Lab Code:	ATSAK C15-0136 (4)
CEI Lab I.D. Range:	CA50831-CA50834

COMPANY INFORMATION	PROJECT INFORMATION
CEI CLIENT #:	Job Contact: Wayne Parker
Company: Wayne Parker	Email / Tel:
Address: 5057 Tangerine Dr. Fayetteville N.C. 28304	Project Name: Fayetteville NC Regional Airport
Email: crfd505@yahoo.com	Project ID#
Tel: 910 309 9179 Fax:	PO #:
	STATE SAMPLES COLLECTED IN: NC.

IF TAT IS NOT MARKED STANDARD 3 DAY TAT APPLIES.

ASBESTOS	METHOD	TURN AROUND TIME					
		4 HR**	8 HR**	24 HR**	2 DAY	3 DAY	5 DAY
LEAD PAINT	EPA SW846 7000B				<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD WIPE	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD SOIL	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD AIR	NIOSH 7082				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
LEAD TCLP	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RCRA 8 METALS	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RCRA 8 TCLP	EPA SW846 7000B				<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER:					<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**TAT IS NOT AVAILABLE. LEAD SAMPLES ARE SUBCONTRACTED FOR ANALYSIS TO AN ELLAP ACCREDITED LAB.

REMARKS:		<input checked="" type="checkbox"/> Accept Samples <input type="checkbox"/> Reject Samples	
Relinquished By:	Date/Time	Received By:	Date/Time
Wayne Parker	4-5-15 5:00 pm		4/8/15 1535

Samples will be disposed of 30 days after analysis

C15-0136

METALS SAMPLING FORM



COMPANY CONTACT INFORMATION	
Company: <i>Wayne Parker</i>	Job Contact: <i>Wayne Parker</i>
Project Name: <i>Fayetteville Regional Airport</i>	
Project ID #:	Tel: <i>910 309 9179</i>

SAMPLE ID#	DESCRIPTION / LOCATION	VOLUME/AREA	COMMENTS
<i>1</i>	<i>Ceiling R 307</i>		
<i>2</i>	<i>Ceiling Wall R- 309</i>		
<i>3</i>	<i>Wall R- 245</i>		
<i>4</i>	<i>Ceiling R 248</i>		